

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7161-0060:104 Page 1 of 1

CATEGORY: Cables-Fire Protective Signaling

LISTEE: Belden Wire & Cable Co., P.O. Box 1980, Richmond IN 47375-1980
Contact: Gerald Lee Dorna (765) 983-5200

DESIGN: Type FPLP power-limited fire protective signaling cable. Refer to listee's data sheet for detailed product description and operational considerations.

Insulation: PVC compound X30800-X30899.

Shields: (Optional) Aluminum/Polypropylene tape.

Core Wrap: (Optional) Polypropylene tape.

Braid: (Optional) Tinned or untinned copper or aluminum.

Jacket: PVC Compound X30800-X30899.

INSTALLATION: In accordance with listee's printed installation instructions, NEC Article 760, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, type, classification and UL label.

APPROVAL: Listed as power-limited fire protective signaling cable.

08-01-96



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **APRIL 9, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy
Program Manager